## FIRE SAFETY CERTIFICATE

No. 23/2024

Dated: 15.04.2025

Certified that the THE NILGIRIS PUBLIC SCHOOL (name of the Building or premises) at T.S.NO.K/10/14 D.No.300,300A, TERFALLS, GRAND DUFF ROAD,LOVEDALE,UDHAGAMANDALAM, THE NILGIRIS – 643 003 (address) comprised of GROUND FLOOR basement(s) and 1st, 2nd FLOORS (upper floors) owned / occupied by THE NILGIRIS PUBLIC SCHOOL (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rue of State / UT Fire service Rules, and verified by the officers concerned of Fire Service on 14.04.2025 (date of inspection) in the presence of Mrs.REMA PADMANABHAN (name and addresses of the Manager / Secretary or his representative) and that the building / premises is fit for occupancy up to classes XIIIth STANDARD (X / XII) with effect from 15.04.2025 for a period of ONE year in accordance with rule and subject to compliance of specific conditions as appended

- 1. FIRE EXTINGUISHES TO BE REFILLED PROPERLY
- 2. FIRE BUCKETS TO BE REFILLED PROPERLY
- 3. EVACUATION DRILL TO BE CONDUCTED EVERY YEAR
- 4. EMERGENCY EXIT TO BE AVAILABLE FREE WITHOUT OBSTACLES AT ANY TIME

Issued on 15.04.2025 (date of issue) at UDHAGAMANDALAM (place) by

\*Strike out whichever is not applicable

Signature with Seal

FIRE AND RESQUE, SERVICE NILGIRIS-643 001 OOTACAMUND,

Name

S. SRIDHAR.

Designation

Name & address of Department / Office:

To,

THE HEADMASTER,
THE NILGIRIS PUBLIC SCHOOL,
GRAND DUFF ROAD,LOVEDALE,
THE NILGIRIS.

தகமன்டலம்,

(Name & Address of the Institution)

## **ENDORSEMENT**

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to (reasons to be recorded)

(Name and designation of the authorized signatory)

<sup>\*</sup> The filled up certificate should be either in Hindi or English. If it is Issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.